



कार्यालय नगर निगम ग्रेटर, जयपुर
(पण्डित दीनदयाल उपाध्याय भवन, लाल कोठी, टोंक रोड़, जयपुर-15)

क्रमांक:-एफ-20()/अधि.अभि.(वि.)/ननिग्रेज/2025/1030 दिनांक:- 12.02.2025

Corrigendum

नगर निगम ग्रेटर जयपुर की ओर से विद्युत कार्य हेतु ई-टेंडरिंग प्रक्रिया में ऑन लाईन निविदा आमंत्रित की गयी निविदा संख्या 133 वर्ष 2024-25 में शर्त संख्या 13 एवं निविदा की डाउन लोड, अपलोड व प्राप्ति तिथि निम्नानुसार संशोधित किया जाता है:-

शर्त संख्या	शर्त	संशोधित शर्त
13	Bidder should be submit the authorization certificate issued by original equipment manufacturer & make, model no. & technical specification of DG set with the technical bid. without this financial bid is not be opend. The Successful bidder can not change the make of DG set during the execution of work he shall complete the work as per the above certificate.	Bidder have to submit make, model no. & technical specification of DG set with the technical bid on his letter head. without this financial bid is not be opend. The OEM Certificate with clearly indicating the same model number & guaranty, warranty is required at the time of LOA. If the bidder fails to provide the OEM Certificate the EMD will be forfeited and bidder will be de-barred as per RTPP Act & Rules.

उक्त शर्त संख्या 13 संशोधित शर्तानुसार पढ़ा जावे। शेष सभी नियम व शर्तें यथावत रहेगी।

डाउन लोड व अपलोड की अंतिम तिथि - दिनांक 20.02.2025 सायं 6.00 बजे तक
निविदा प्राप्ति/खोलने की तिथि - दिनांक 21.02.2025 प्रातः 11.00 बजे

निविदा से सम्बन्धित समस्त विवरण वेब साईट <http://eproc.rajasthan.gov.in> पर निम्न UBN No. JMC2425@GLOB01246 पर देखा जा सकता है।

(प्रदीप कुमार शर्मा)
अधिकाधी अभियन्ता (विद्युत)
नगर निगम ग्रेटर जयपुर

Validity unknownSignature valid

Digitally signed by Pradeep Kumar
Sharma
Designation : Independent Engineer
Date: 2025.02.12 15:37:29 IST
Reason: Approved



XEN Light Hindi Letters Page | 1

RajKaj Ref No.: 13551094

विषय:- निविदा संख्या 133/2024-25 की प्री-बिड के संबंध में।

दिनांक 05.02.2025 को ई-निविदा संख्या 133/2024-25 की प्री-बिड मितिग आयोजित की गई मितिग में निम्न फर्मों द्वारा उक्त निविदा के संबंध में अपने सुझाव प्रस्तुत किये गये, अतः फर्मों द्वारा दिये गये सुझावों पर निम्नानुसार निर्णय लिया गया।

S.N	Name of firm	Tender Condition	Observation & suggestion	Committee decision
1		The work Shall Comprise of entire labour, including Supervision and all materials neccessary to make complete installation and such tests and adjustment on commissioning as may be required by the department.		As per tender document.
2		Maintenance (Routine & Preventive) for one year from date of Completion.		As per tender document.
3		Copies of all documents of routine and type test certificate of the equipment, carried out at the manufacturers premises. Shall he furnished to the Engineer incharge during the factory inspection.		As per tender document.
4		Make of D. G. set :- Cummins / Kirloskar/Sudhir Power/Mahindra Powerrol.		As per tender document.
5	A K Electricals	D. G. Set Shall be compliance the latest CPCB norms.	D. G. Set Shall be compliance the latest CPCB IV norms & as per 804(E) dated 03.11.2022 & notification no. Q15017/05/2022	D. G. Set Shall be compliance the latest CPCB iv norms. as per the government of india notification. Also DG set should be accordance to with GSR-804(E)dated 03.11.2022 & MOEFCC Notification No. Q-15017/05/2022 CP and complied with above standard certificate should be submitted for same in tender document without will tender not be accepted.

Hussain

6	A K Electricals	Successful Bidder has to install and Connect the DG set to the Existing AMF Panel & Transformer and if required he has to modify the AMF panel for proper functioning of DG set through AMF panel. No Extra Cost for the above work will be paid to the bidder.	Automatic transfer switch is required in AMF panel for automation.	Successful Bidder has to install and Connect the DG set to the Existing AMF Panel & Transformer and if required he has to modify the AMF panel for proper functioning of DG set through AMF panel. No Extra Cost for the above work will be paid to the bidder. If require automatic transfer switch will be supply & install by the successful bidder the cost of automatic transfer switch will be pay as per RUIDP/PWDBSR Sepcification & Rates.
7		The equipment offered shall confirm to the specification has given in tender.		As per tender document.
8		All Civil work related to DG set platform will be done as per specification.		As per tender document.
9		gurranteed against defective design in manufacturing defect for minimum period of 12th month after completion of work.		As per tender document.
10		Work must be done in mentioned time period.		As per tender document.
11	A K Electricals		There is no detail mention in tender regarding telematic system to capture the DG parameter.	DG Should have proper telematic system to capture the DG parameter & address BMS request over RS 485 interface, divide should be 4G compliance and compatible with all the controller
12	A K Electricals		Electric wiring item mention in BOQ, Scope of work is not clear regarding this item.	Electric wiring item mention in boq will be use to distribute & segregate the load of AC units as per the direction of engineer incharge

M. Kumar

13			Bidder should be submit the authorization certificate issued by original equipment manufacturer & make, model no. & technical specification of BG set with the tender without this tender will not be accepted also successful bidder can not change the make of DG set during the execution of work he shall complete the work as per the above certificate.	Bidder should be submit the authorization certificate issued by original equipment manufacturer & make, model no. & technical specification of DG set with the technical bid. without this financial bid is not be open. The Successful bidder can not change the make of DG set during the execution of work he shall complete the work as per the above certificate.
14	A K Electricals		As per the office order issued by the office of Director of local bodies, bidder should be experienced in SICT of DG set in any government.	Rejected.

उक्तानुसार प्रतिउत्तर तैयार कर पोर्टल पर अपलोड करने का निर्णय लिया गया।

Assistant Engineer (L)
Nagar Nigam Greater Jaipur

Assistant Accounts Officer
Nagar Nigam Greater Jaipur

Superintendent/ Executive Engineer (L)
Nagar Nigam Greater Jaipur

Financial Adviser
Nagar Nigam Greater Jaipur

कार्यालय नगर निगम ग्रेटर, जयपुर
(पण्डित दीनदयाल उपाध्याय भवन, लाल कोठी, टॉक रोड, जयपुर-15)

क्रमांक:-एफ-20()/अधि.अभि.(वि.)/ननिग्रेज/2025/991 दिनांक:- 03.02.2025

निविदा सूचना सं. 133/वर्ष 2024-25

नगर निगम ग्रेटर जयपुर की ओर से निम्न विद्युत कार्य हेतु नगर निगम ग्रेटर जयपुर में व अन्य विभागों में नये नियमों के नियमानुसार श्रेणीवार E-1 श्रेणी में पंजीकृत संवेदकों से निम्न कार्य हेतु निर्धारित प्रपत्र में ई-प्रोक्यूरमेंट-हेतु ऑनलाईन निविदा आमंत्रित, की जाती हैं।

कार्य का विवरण	सम्बन्धित अधिकारी का नाम
नगर निगम ग्रेटर जयपुर मुख्यालय भवन में 500 केवीए जीजी सेट की आपूर्ति एवं स्थापना एवं संबंधित आवश्यक विद्युतीकरण कार्य। वर्ष 2024-25	Executive Engineer (Light)
Cost of tender (document non-refundable) in favor of municipal corporation greater Jaipur, payable at jaipur.	1500/-
RISL processing fee (non-refundable) in favor of Managing Director RISL, payable at jaipur.	1500/-
Estimate cost	68,29,293/-
Work Period	04 Month
Earnest money deposit	0.50% (Rs.34,147.00) of the estimated amount of work from registered contractors in Municipal Corporation Jaipur.And 2% (Rs.1,36,586.00) from the contractors registered in other departments.
Tender publication on official web site http://eproc.rajasthan.gov.in	04.02.2025 11.00 AM
Tender download start date	04.02.2025 01.00 PM
Pre bid meeting	05.02.2025 11.00 AM
Bid submission start date	07.02.2025 11.00 AM
Bid submission end date	17.02.2025 06.00 PM
Technical bid Opening date/time	18.02.2025 11.00 AM
Financial Bid (Envelop- 2 Opening)	तकनीकी निविदा सफल होने पर ही वित्तीय निविदा खोली जाएगी।

निविदा दाताओं को निविदा शुल्क, अमानता राशि एवं प्रोसेसिंग फीस ऑनलाईन स्थानीय निकाय विभाग, राज0, जयपुर की वेबसाईड www.jaipurmc.org पर Submission Date and time से पूर्व जमा करवाकर उससे प्राप्त होने वाली रसीद को स्कैन करके रजिस्ट्रेशन WWW.eproc.rajasthan.gov.in & <http://sppp.rajasthan.gov.in> पर अपलोड करने पर ही निविदा को मान्य किया जायेगा एवं संवेदक द्वारा तकनीकी निविदा में निम्न दस्तावेज - रजिस्ट्रेशन, विद्युत लाईसेंस की छाया प्रति तथा, Pan card, PF,ESI, GST में पंजीयन की छाया प्रति एवं संवेदक की हस्ताक्षरित Annexure A,B,C,D,E एवं हस्ताक्षरित निविदा शर्तें स्कैन कर अपलोड करना अनिवार्य है। उक्त दस्तावेज हस्ताक्षरित अपलोड नहीं करने पर सम्बन्धित संवेदक की निविदा को मान्य नहीं माना जावेगा, एवं ऑन लाईन निविदा प्रपत्र डाउनलोड/अपलोड करने की अवधि उपरांत ऑफ लाईन दस्तावेज नहीं लिये जायेंगे। राज्य सरकार द्वारा जारी वर्तमान में प्रचलित नियम प्रभावी रहेंगे।

निविदा में वित्त विभाग की अधिसूचना 2021 द्वारा RTPP Act 2013 के अन्तर्गत शामिल किये गये नियम 75 ए की पालना संवेदक द्वारा की जावेगी जिसके अनुसार Unbalanced Bid होने की दशा में नियमानुसार अतिरिक्त कार्य प्रतिभूति (Additional Performance Security) राशि BG/FDR के रूप में LOA जारी होने के 14 दिवस में प्रस्तुत किया जाना आवश्यक है। यदि संवेदक द्वारा Additional Performance Security राशि जमा कराने के पश्चात् कार्य संतोषजनक रूप से पूर्ण नहीं करता है तो उसकी Additional Performance Security राशि नगर निगम ग्रेटर जयपुर द्वारा जब्त कर ली जावेगी व अनुबन्ध के तहत अन्य कार्यवाही भी अमल में लायी जावेगी। निविदा से सम्बन्धित समस्त विवरण वेबसाईट <http://eproc.rajasthan.gov.in> & <http://sppp.rajasthan.gov.in> तथा www.jaipurmc.org पर देखा जा सकता है। इच्छुक संवेदकों को अपने डिजिटल दस्तावेज को माध्यम से वेबसाईट पर रजिस्टर्ड करवाना आवश्यक है।

Signature valid

Digitally signed by Pradhep Kumar Sharma
(प्रदीप कुमार शर्मा)
Designation : Supervisor (विद्युत)
Date: 2025.02.03 11:30:29
Reason: Approved

